### **GENERAL TECHNOLOGY NOTES:**

- "8/T501" INDICATES DETAIL NUMBER / SHEET NUMBER. 2. "SC-ER-1" INDICATES GENERAL TECHNOLOGY EQUIPMENT SCHEDULE ITEM LABELED AS "EQUIPMENT LIST ABBREVIATION".
- 3. A SLASH IS USED BETWEEN TWO SUBSCRIPTS, i.e. A/H 4. REFER TO THE GENERAL TECHNOLOGY EQUIPMENT SCHEDULE AND SPECIFICATIONS FOR FULL DESCRIPTIONS AND MANUFACTURERS OF ALL DEVICES.

"(#)" INDICATES KEYED NOTE USED TO DESCRIBE ADDITIONAL INFORMATION OF WORK

- REQUIRED, SPECIFIC TO THE SHEET AND/OR DETAIL IT IS SHOWN WITH.
- FROM FINISHED FLOOR TO CENTERLINE MOUNTING SUBSCRIPT KEY: TECHNOLOGY OUTLETS MOUNT ABOVE COUNTER (+6" TO CENTERLINE ABOVE COUNTER OR BACKSPLASH) MOUNT IN LAB CASEWORK

#### MOUNT HORIZONTAL ABBREVIATION KEY

J-BOX

TECHNOLOGY CONTRACTOR SECURITY CONTRACTOR AUDIO/VISUAL CONTRACTOR NURSE CALL CONTRACTOR ELECTRICAL CONTRACTOR

MECHANICAL CONTRACTOR

- GENERAL CONTRACTOR AFF ABOVE FINISH FLOOR
- BFC BELOW FINISHED CEILING CONDUIT SIMILAR
- MOUNTING HEIGHT ABOVE FINISHED FLOOR

## TELECOM ROOM ABBREVIATION KEY:

ENTRANCE FACILITY HORIZONTAL CROSS-CONNECT INTERMEDIATE CROSS-CONNECT

JUNCTION BOX

MC-# MAIN CROSS-CONNECT TELECOMMUNICATIONS ROOM

NEW WORK BY THIS CONTRACTOR (DARK SOLID LINE) — NEW WORK UNDERFLOOR OR UNDERGROUND BY THIS CONTRACTOR (DARK LONG

NEW WORK BY OTHERS, AND/OR EXISTING TO REMAIN (LIGHT SOLID LINE) ---- EXISTING TO BE REMOVED BY THIS CONTRACTOR (DARK SHORT DASHED LINE)

## **TECHNOLOGY INSTALLATION NOTES:**

- 1. THE COMPLETE INSTALLATION SHALL BE IN ACCORDANCE WITH THE 2010 ADA STANDARDS FOR ACCESSIBLE DESIGN. REFER TO THE ADA REQUIREMENTS FOR ALL CONFIGURATIONS DETAIL ON THIS
- PAGE FOR ADDITIONAL INFORMATION. CONCEAL ALL CONDUIT IN WALLS, PARTITIONS, ABOVE CEILING, AND IN FLOOR SLAB, ETC. UNLESS OTHERWISE INDICATED ON THE PLANS OR IN THE SPECIFICATIONS. CONDUIT IN MECHANICAL ROOMS,
- AND STORAGE ROOMS WITHOUT CEILINGS MAY BE EXPOSED ON BUILDING STRUCTURE. 3. BOXES LOCATED ON OPPOSITE SIDES OF NON-RATED WALLS SHALL BE OFFSET A MINIMUM OF 6" HORIZONTALLY. BOXES ON OPPOSITE SIDES OF FIRE RATED WALLS SHALL BE OFFSET A MINIMUM
- OF 24" HORIZONTALLY. "THRU-THE-WALL" BOXES SHALL NOT BE ALLOWED WITHOUT PRIOR WRITTEN APPROVAL OF THE ARCHITECT/ENGINEER. CONTRACTOR SHALL VERIFY ALL FURNITURE, MODULAR FURNITURE AND EQUIPMENT LOCATIONS WITH ARCHITECTURAL PLANS, ELEVATIONS AND REVIEWED SHOP DRAWINGS. PRIOR TO MAKING THE
- ACTUAL TELECOMMUNICATIONS INSTALLATION THIS CONTRACTOR SHALL ADJUST OUTLETS OR CONNECTION LOCATIONS TO ACCOMMODATE FURNITURE AND/OR EQUIPMENT. TELECOMMUNICATIONS EQUIPMENT SHALL BE MOUNTED TO ALLOW ACCESS TO ELECTRICAL AND MECHANICAL EQUIPMENT. ALL MOUNTING OF TELECOMMUNICATION DEVICES ON EQUIPMENT
- SUPPLIED BY ANOTHER CONTRACTOR SHALL BE APPROVED IN ADVANCE BY THE OTHER CONTRACTOR. 6. CONTRACTOR SHALL BE RESPONSIBLE FOR ALL OPENINGS REQUIRED IN WALLS. ALL OPENINGS SHALL BE REPAIRED TO MATCH EXISTING BY A QUALIFIED CONTRACTOR AT THE EXPENSE OF THIS
- CONTRACTOR. ALL CONDUITS THROUGH WALLS SHALL BE GROUTED OR SEALED INTO OPENINGS. ALL MATERIALS USED TO SEAL PENETRATIONS OF FIRE RATED WALLS AND FLOORS SHALL BE TESTED AND CERTIFIED AS A SYSTEM PER ASTM E814 STANDARDS FOR FIRE TESTS OF THROUGH-
- PENETRATION FIRESTOPS. CONTRACTOR SHALL REMOVE AND REINSTALL ALL CEILING TILES AS REQUIRED FOR THE EXECUTION OF TELECOMMUNICATIONS WORK THAT IS OUTSIDE THE CONTRACT LIMITS OF CONSTRUCTION. CONTRACTOR SHALL REPLACE CEILING TILES WITH IDENTICAL MATERIAL WHERE DAMAGED BY THIS
- CONTRACTOR. FIRESTOPPING REFERS TO THE ITEMS SPECIFICALLY ADDRESSED IN DIVISION 26, 27 AND 28 DOCUMENTS. REFER TO THE INDIVIDUAL SPECIFICATION SECTIONS FOR INFORMATION SPECIFIC TO
- 10. ALL "LADDER RACK" AND "CABLE TRAY" SIZES ARE AS DEFINED ON THE DRAWINGS. REFER TO SPECIFICATIONS SECTION 27 05 28 AND 27 11 00 FOR APPROVED MANUFACTURERS AND INSTALLATION REQUIREMENTS.

### TECHNOLOGY SHEET INDEX

T000	TEC
T001	SITE
T100	BAS
T101	FIRS
T102	OVE
T103	ENL
T104	ENL
T105	ROC
T106	OVE
T401	ROC

T502

VA FORM 08-6231, OCT 1978

- CHNOLOGY COVER SHEET E PLAN - TECHNOLOGY SEMENT FLOOR PLAN - TECHNOLOGY RST FLOOR PLAN - TECHNOLOGY - DEMO
- ERALL FIRST FLOOR PLAN ADDITION AND RENOVATION TECHNOLOGY LARGED PLAN - AMBULATORY CARE - TECHNOLOGY LARGED FLOOR PLAN - LABORATORY AND SECURITY - TECHNOLOGY
- OOF PLAN TECHNOLOGY ERALL FIRST FLOOR PLAN - ADDITION AND RENOVATION ALT. - TECHNOLOGY OOM ENLARGEMENTS - TECHNOLOGY
- DETAILS TECHNOLOGY DETAILS - TECHNOLOGY
- SCHEDULES TEHCNOLOGY

#### **TECHNOLOGY DEMOLITION NOTES:**

- 1. THE TECHNOLOGY DRAWINGS INDICATE EXISTING TECHNOLOGY ITEMS TO BE REMOVED. THE DRAWINGS ARE INTENDED TO INDICATE THE SCOPE OF WORK REQUIRED AND DO NOT INDICATE
- EVERY BOX, CONDUIT, OR WIRE THAT MUST BE REMOVED. THE CONTRACTOR SHALL VISIT THE SITE PRIOR TO SUBMITTING A BID AND VERIFY EXISTING CONDITIONS. 2. ITEMS (i.e. SPEAKERS, SWITCHES, ETC) REMOVED AND NOT RELOCATED REMAIN THE PROPERTY OF THE OWNER. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE DISPOSAL OF MATERIAL THE OWNER DOES NOT WANT TO REUSE OR RETAIN. (i.e., FOR MAINTENANCE
- THE CONTRACTOR SHALL OBTAIN APPROVAL FROM THE OWNER BEFORE TURNING OFF THE POWER TO EQUIPMENT, SYSTEMS, PANELS, ETC. COORDINATE ALL OUTAGES WITH OWNER. CONDUIT CONCEALED IN WALL CONSTRUCTION MAY BE ABANDONED IN PLACE IF NOT AFFECTED BY OTHER CONSTRUCTION. 4. ALL CONDUIT SHALL BE REMOVED WHERE WALLS ARE BEING REMOVED. WHERE CONDUIT IS IN
- THE CONCRETE SLAB, CUT OFF FLUSH, PULL OUT WIRE, AND PLUG. WHERE CONDUIT IS RUN EXPOSED, ALL ASSOCIATED CLAMPS, SUPPORTS, HANGERS, ETC., SHALL ALSO BE REMOVED. THIS CONTRACTOR SHALL COORDINATE ALL THEIR WORK WITH OTHER CONTRACTORS AT THE JOB SITE BEFORE REMOVING EXISTING EQUIPMENT AND INSTALLING NEW ITEMS. EXISTING CONDUIT IN GOOD CONDITION, MAY BE REUSED IN PLACE. RELOCATING EXISTING
- CONDUIT SHALL NOT BE ALLOWED. BONDING CONDUCTORS SHALL BE INSTALLED IN ALL REUSED CONDUIT TO ASSURE PROPER GROUND PATH. EQUIPMENT REMOVAL IN CERTAIN LOCATIONS MAY REQUIRE THE INSTALLATION OF A JUNCTION BOX TO RECONNECT CIRCUITS THAT REMAIN IN OPERATION. EXTEND CONDUIT AND
- TECHNOLOGY DEVICES TO BE REMOVED SHALL HAVE ALL CONNECTED WIRING REMOVED TO THE SOURCE.
- 9. DEVICES NOT TO BE REMOVED SHALL BE PROTECTED FROM THE ENVIRONMENT, AND ALL ASSOCIATED CABLE/RACEWAYS ARE TO REMAIN AND BE PROTECTED. T.C. SHALL BE RESPONSIBLE FOR REPAIR OF ANY INTERRUPTIONS TO PROTECTED DEVICES.

WIRING AS REQUIRED TO MAINTAIN POWER TO REMAINING EQUIPMENT.

SUGGESTED MATRIX OF SCOPE RESPONSIBILITY FURNISHED INSTALLED SHOWN ON BY BY TECHNOLOGY ROUGH-IN, REFER TO GENERAL TECHNOLOGY EQUIPMENT SCHEDULE AND T-SERIES SPECIFICATIONS FOR DEFINITION INFORMATION OUTLET FACEPLATES, JACKS AND TERMINATIONS T-SERIES CONDUIT SLEEVES (WHEN SHOWN ON DRAWINGS) T-SERIES CONDUIT SLEEVES (NOT SHOWN BUT REQUIRED FOR PROPER INSTALLATION OF SYSTEM) TELECOMMUNICATION SYSTEMS ROUGH-IN T-SERIES T-SERIES TELECOMMUNICATION EQUIPMENT, CABLING, & TERMINATIONS T-SERIES NURSE CALL ROUGH-IN T-SERIES NURSE CALL EQUIPMENT, CABLING, & TERMINATIONS CABLE TRAY (INCLUDING WIRE BASKET TRAY) REFER TO SPECIFICATION SECTION 27 05 28 FOR T-SERIES DEFINITION LADDER RACK T-SERIES GROUNDING LUGS ON TECHNOLOGY EQUIPMENT T-SERIES BONDING SYSTEM FOR TECHNOLOGY SYSTEM, REFER TO SPECIFICATION SECTION 27 05 26 FOR T-SERIES CONNECTION OF TECHNOLOGY BONDING SYSTEM TO THE ELECTRICAL GROUND SYSTEM T-SERIES LINE VOLTAGE POWER (+120V OR GREATER) E-SERIES LINE VOLTAGE POWER (NOT SHOWN BUT REQUIRED FOR PROPER INSTALLATION OF SYSTEM) LINE VOLTAGE POWER FOR DOOR HARDWARE POWER SUPPLIES **ARCH SPEC** LOW VOLTAGE CABLING FOR TECHNOLOGY SYSTEMS T-SERIES BRIDLE RINGS OR OTHER CABLE ROUTING METHODS (OTHER THAN CONDUIT AND CABLE TRAY) T-SERIES TECHNOLOGY SERVICE ENTRANCE CONDUITS, HANDHOLES, & MANHOLES T-SERIES T & E SERIES FLOOR BOX (ROUGH-IN)

#### SCOPE OF RESPONSIBILITY NOTES

- 1. LOCATIONS OF TELECOMMUNICATIONS ROUGH-IN SHALL BE INDICATED BY THE INFORMATION OUTLET SYMBOL ON THE CONTRACT DOCUMENTS. REFER TO THE
- TECHNOLOGY SYMBOL LIST FOR ADDITIONAL INFORMATION. 2. BASED ON THE INHERENT DIFFERENCES IN PRODUCTS FROM VARIOUS MANUFACTURERS, ALL REQUIRED EQUIPMENT MAY NOT BE SHOWN ON THE DRAWINGS FOR
- ALL ACCEPTABLE MANUFACTURERS. 3. INCLUDES BACKBOXES AND CONDUIT REQUIRED FOR THE TECHNOLOGY SYSTEMS INSTALLATION. THE E.C. SHALL BASE THE BID ON THE BASIS OF DESIGN SHOWN
- ON THE CONTRACT DOCUMENTS. 4. ALL CHANGES TO THE SLEEVES, BACKBOXES, CONDUITS AND POWER REQUIRED BECAUSE OF THE T.C.'S SELECTION OF AN ALTERNATE ACCEPTABLE MANUFACTURER (OR FROM SYSTEM CONFIGURATIONS THAT ARE LEFT TO THE CHOICE OF THE CONTRACTOR) SHALL BE INCLUDED IN THE T.C.'S BID. THIS BID SHALL INCLUDE INSTALLATION BY A LICENSED ELECTRICIAN.
- 5. UNLESS TRADE RULES DICTATE OTHERWISE.
- 6. FURNISHED AS PART OF THE EQUIPMENT WHEN POSSIBLE, OR FURNISHED TO THE E.C. FOR INSTALLATION IN THE FIELD. 7. INCLUDES ALL CONDUCTORS, GROUND BARS, AND TERMINATION'S FOR THE COMPLETE GROUNDING SYSTEM REQUIRED BY THE SPECIFICATIONS.
- 8. REFER TO ELECTRICAL DRAWINGS FOR LOCATIONS OF PANELS AND SWITCHBOARDS SHOWN IN THE GROUNDING RISER.


TELECOM ROOM REFERENCES				
TELECOM DETAIL/SHEET FLOOR ROOM REFERENCE REFER				
HC-1	1/T401	T103		
HC-2	3/T104	1/T104		
HC-3	4/T104	2/T104		
MCR-1	T100	T100		

	INFORMATION OUTLET SCHEDULE							
		I, THE IN	FORMA <sup>*</sup>	TION OL	JTLET DI	ETAILS A	AND T60	END FOR POSITION JACK TYPE 01 GENERAL TECHNOLOGY FORMATION.
			FAC	EPLATE	FEATU	RES		
CONFIGURATION	FACEPLATE PORTS	POSITION 1 JACK TYPE	POSITION 2 JACK TYPE	POSITION 3 JACK TYPE	POSITION 4 JACK TYPE	POSITION 5 JACK TYPE	POSITION 6 JACK TYPE	SCHEDULE NOTES
▼ <b>▼</b> 1V 3D	4	DATA	DATA	DATA	VOICE			
<b>▼</b> 1D	1	DATA						
<b>▼</b> W	1	VOICE						1
<b>₩</b> AP	1	DATA						1.
<b>▼</b> 2D	2	DATA	DATA					
<b>▼</b> AV	2	HDMI						
<b>▼</b> M	1	CATV						

NOTES:
1. LOCATION OF FUTURE WIRELESS ACCESS POINT. PROVIDE A 20' SLACK COIL AT NEAREST CABLE SUPPORT FOR POSSIBLE

INFORMATION OUTLET SCHEDULE				
JACK TYPE	IO SCHEDULE DESCRIPTION			
BLANK	BLANK FILLER MODULE			
CATV	RG 6 F-CONNECTOR			
DATA	CAT 6 RJ-45			
HDMI	HDMI CONNECTOR			
VOICE	CAT 6 RJ-45			

RELOCATION AFTER FUTURE RF SURVEY.




		CHNOLOGY SYMBOL LIST	
SYMBOL	EQUIPMENT LIST ABBREVIATION	DESCRIPTION	NOTE
₩AP	<u>SC-WAP-C</u>	CEILING INFORMATION OUTLET, DATA COMMUNICATION ONLY, WIRELESS ACCESS POINT	
## <b>V</b>	SC-IO-W	WALL INFORMATION OUTLET, COMBINATION TELEPHONE/DATA COMMUNICATION	1.
W	SC-WP-W	WALL INFORMATION OUTLET, WALL TELEPHONE COMMUNICATION	
# # <b>©</b>	<u>SC-IO-C</u>	CEILING INFORMATION OUTLET, COMBINATION TELEPHONE/DATA COMMUNICATION	
# #	<u>SC-IO-F</u>	FLOOR INFORMATION OUTLET, COMBINATION TELEPHONE/DATA COMMUNICATION	
MAS T	SC-EM-1	EMERGENCY PHONE MASTER STATION	
AV	<u>AV-RI</u>	AV OUTLET	
M V	<u>SC-TV-RI</u>	TELEVISION OUTLET	
MAS	NC-MAS-W	MASTER STATION	
S	<u>VA-S-C</u>	FACILITY PAGING SPEAKER (CEILING)	
Ф	<u>VA-H-W</u>	FACILITY PAGING HORN (WALL)	
HN)	NC-D-C	NURSE CALL DOME LIGHT	
HN <sub>T</sub>	<u>NC-T-W</u>	NURSE CALL TOILET STATION	
HNE	NC-E	NURSE CALL EMERGENCY STATION	
HND	NC-DTY-W	NURSE CALL DUITY STATION	
AV	AV-WP1-C	AV WALLPLATE (CEILING) - TYPE 1	
WP1	AV-WP1-W	AV WALLPLATE (WALL) - TYPE 1	
CSS	N.A.	CONTROLLED SECURITY SCHEME SCHEDULE IDENTIFIER	
НН	PW-HH-1	HAND HOLE	
EM <b>T</b>	SC-EM-1	EMERGENCY PHONE	
Д <sub>D</sub>	AC-PB-1	PANIC BUTTON	
□ w s	AC-CR-1	CARD READER	
w	AC-CR-2	DUAL AUTHENTICATION CARD READER	

- ALL SYMBOLS AND ABBREVIATIONS LISTED MAY NOT BE APPLICABLE TO THIS PROJECT. REFER TO THE GENERAL TECHNOLOGY EOLIDMENT SCHEDULE FOR MORE COMPLETE DESCRIPTION AND ITEMS
- ALL SYMBOLS AND ABBREVIATIONS REFER TO TECHNOLOGY SHEETS ONLY AS DEFINED ON THE SHEET INDEX. REFER TO THE GENERAL TECHNOLOGY NOTES FOR ADDITIONAL INFORMATION. ALL SYMBOLS LISTED ABOVE ARE FOR REFERENCE ONLY. REFER TO PLANS AND LINE TYPES KEY FOR NEW, EXISTING TO REMAIN AND TO BE REMOVED ITEMS FOR ADDITIONAL INFORMATION.

### **TECHNOLOGY SYMBOL NOTES:**

- "C#" INDICATES INFORMATION OUTLET FACEPLATE CONFIGURATION. REFER TO INFORMATION OUTLET SCHEDULE ON T-000 FOR ADDITIONAL INFORMATION. SYMBOL SUBSCRIPT INDICATES DEVICE TYPE, REFER TO EQUIPMENT SCHEDULE FOR ADDITIONAL INFORMATION.
- REFER TO CONTROLLED SECURITY SCHEME (CSS) TYPE SCHEDULE ON T601 FOR ADDITIONAL INFORMATION. INFORMATION OUTLET INSTALLED IN E.C. PROVIDED FLOOR BOX. "C#" INDICATES INFORMATION OUTLET FACEPLATE CONFIGURATION. REFER TO INFORMATION OUTLET SCHEDULE ON T-000 FOR ADDITIONAL INFORMATION. REFER TO THE ELECTRICAL FLOOR PLANS AND ELECTRICAL EQUIPMENT SCHEDULE FOR ADDITIONAL INFORMATION.



ADA GUIDELINES - SIDE ACCESS **ADA GUIDELINES FOR ALL CONFIGURATIONS** 


INSTALL DEVICE OR INFORMATION


OUTLET AT 42" ABOVE FINISHED FLOOR.

INSTALL DEVICE OR INFORMATION

OUTLET AT 44" ABOVE FINISHED FLOOR.

	CONSULTANTS:	ARCHITECT:	Drawing Title	Project Title RENOVATE AND EXPAND AMBULATORY CARE AND LAB	Project Number 549-130	Ott: t
	HEALTHCARE PLANNERS: VOA ARCHITECTS  MEPFP + TECH + STRUCT: KJWW CONSULTING ENGINEERS	MICHAEL ROTH & ASSOCIATES,	TECHNOLOGY COVER SHEET	SAM RAYBURN MEMORIAL VETERANS CENTER		Office of Facilities
	CIVIL ENGINEER: JD ENGINEERING	ARCHITECTS & PLANNERS, INC.	Approved: Project Director	Location BONHAM, TEXAS	Drawing Number	Management
Revisions:	COST ESTIMATING: MOSS CONSTRUCTION COST MANAGEMENT INDUSTRIAL HYGIENE: JOHN A. JURGIEL & ASSOCIATES, INC.	200 SOUTH HANLEY ROAD, STE. 1105, CLAYTON, MISSOURI 63105, 314-862-2112		Date APRIL 13, 2015  Checked Drawn KEIEVE	T000 Dwg. 130 of 142	Department of Veterans Affairs








	CONSULTANTS:	ARCHITECT:	Drawing Title  BASEMENT FLOOR PLAN -	Project Title RENOVATE AND EXPAND  AMBULATORY CARE AND LAB.  SAM RAYBURN MEMORIAL	Project Number 549-130  Building Number	Office of
	HEALTHCARE PLANNERS: VOA ARCHITECTS  MEPFP + TECH + STRUCT: KJWW CONSULTING ENGINEERS  CIVIL ENGINEER: JD ENGINEERING	MICHAEL ROTH & ASSOCIATES, ARCHITECTS & PLANNERS, INC.	TECHNOLOGY  Approved: Project Director	VETERANS CENTER  Location BONHAM, TEXAS	T Drawing Number	Facilities Management
Revisions: Date	COST ESTIMATING: MOSS CONSTRUCTION COST MANAGEMENT INDUSTRIAL HYGIENE: JOHN A. JURGIEL & ASSOCIATES, INC.	200 SOUTH HANLEY ROAD, STE. 1105, CLAYTON, MISSOURI 63105, 314-862-2112		Date APRIL 13, 2015  Checked Drawn KEIEVE	T100 Dwg. 132 of 142	Department of Veterans Affairs


1 2 5

VA FORM 08-6231, OCT 1978









## **ENLARGED LABORATORY FLOOR PLAN - TECHNOLOGY**

NOTES:


1. REFER TO T000 FOR GENERAL TECHNOLOGY NOTES.

2. REFER TO T000 FOR TECHNOLOGY SYMBOLS LIST.


- REFER TO T000 FOR INFORMATION OUTLET SCHEDULE.
   REFER TO 2/T501 FOR TELECOM RISER DIAGRAM.
   REFER TO 5/T501 FOR TECHNOLOGY OUTLET ROUGH-IN INFORMATION.
- REFER TO 5/1501 FOR TECHNOLOGY OUTLET ROUGH-IN INFORMATION
   REFER TO 1/T502 FOR OVERHEAD PAGING SYSTEM RISER DIAGRAM.
   REFER TO 2/T502 FOR ACCESS CONTROL RISER DIAGRAM.
- REFER TO 3/T502 FOR NURSE CALL STATION RISER DIAGRAM.
   CONTRACTOR SHALL ROUGH-IN CARD READERS AND DOORS FOR SECURITY SYSTEM. REFER TO DETAIL 6/T-601.
- 10. REFER TO T601 FOR GENERAL TECHNOLOGY EQUIPMENT SCHEDULE.
  11. ALL INFORMATION OUTLET CABLE LOCATIONS ON THIS SHEET SHALL ROUTE TO HC-2.
- KEYNOTES:


  1. CAMERA LOCATION. ROUTE CABLING TO SECURITY SYSTEMS ROOM, REFER TO 1/T401 FOR ADDITIONAL INFORMATION. CAMERA TO BE OWNER FURNISHED AND OWNER INSTALLED.

FURNISHED AND OWNER INSTALLED.
2. CONTRACTOR SHALL ROUGH-IN CARD READERS AND DOORS FOR SECURITY SYSTEM. REFER TO DETAIL 6/T-501









## **ENLARGED SECURITY FLOOR PLAN - TECHNOLOGY**

1. REFER TO T000 FOR GENERAL TECHNOLOGY NOTES.

2. REFER TO T000 FOR TECHNOLOGY SYMBOLS LIST

- REFER TO T000 FOR TECHNOLOGY SYMBOLS LIST.
   REFER TO T000 FOR INFORMATION OUTLET SCHEDULE.
   REFER TO 2/T501 FOR TELECOM RISER DIAGRAM.
- REFER TO 5/T501 FOR TECHNOLOGY OUTLET ROUGH-IN INFORMATION.
   REFER TO 1/T502 FOR OVERHEAD PAGING SYSTEM RISER DIAGRAM.
   REFER TO 2/T502 FOR ACCESS CONTROL RISER DIAGRAM.

10. REFER TO T601 FOR GENERAL TECHNOLOGY EQUIPMENT SCHEDULE.

MOUNTING HEIGHTS WITH ARCHITECTURAL DETAILS PRIOR TO INSTALLATION.

- REFER TO 3/T502 FOR NURSE CALL STATION RISER DIAGRAM.
   REFER TO 4/T502 FOR FIBER AND COPPER RISER DIAGRAM.
- 11. ALL INFORMATION OUTLET CABLE LOCATIONS ON THIS SHEET SHALL ROUTE TO HC-3.
  12. CONTRACTOR SHALL ROUGH-IN CARD READERS AND DOORS FOR SECURITY SYSTEM. REFER TO DETAIL 6/T-501.

KEYNOTES:

1. CAMERA LOCATION. ROUTE CABLING TO SECURITY SYSTEMS ROOM, REFER TO 1/T401 FOR ADDITIONAL INFORMATION. CAMERA TO BE


- OWNER FURNISHED AND OWNER INSTALLED.
  2. PLACE RELOCATED ALARM PANELS ON THIS WALL. COORDINATE EXACT LOCATION WITH OWNER PRIOR TO ROUGH-IN.
  3. RELOCATED ALARM PANELS, REFER TO T101 FOR MORE INFORMATION.
- MOUNT CATV AND UPPER AV OUTLETS AT 66" AFF, VERIFY EXACT MOUNTING LOCATION WITH OWNER/ARCHITECT PRIOR TO INSTALLING ROUGH-IN.
   OUTLETS FOR SECURITY SYSTEM MONITORS VERIFY EXACT CONNECTION TYPE REQUIRED WITH SECURITY SYSTEM CONTRACTOR AND
  - EXISTING RACK. PROVIDE
    NEW SC-MPP-1 FOR NEW
    CABLING IN THIS RACK.


    EXISTING 110 BLOCKS,
    TERMINATE NEW VOICE


CABLES ON EXISTING 110



	CONSULTANTS:	ARCHITECT:	Drawing Title ENLARGED FLOOR PLAN -	Project Title RENOVATE AND EXPAND  AMBULATORY CARE AND LAB.	Project Number 549-130	
	HEALTHCARE PLANNERS: VOA ARCHITECTS  MEPFP + TECH + STRUCT: KJWW CONSULTING ENGINEERS	MICHAEL ROTH & ASSOCIATES.	LABORATORY AND SECURITY - TECHNOLOGY		Building Number  1	Office of Facilities
	CIVIL ENGINEER: JD ENGINEERING	ARCHITECTS & PLANNERS, INC.	Approved: Project Director	Location BONHAM, TEXAS	Drawing Number T104	Management
Revisions:	COST ESTIMATING: MOSS CONSTRUCTION COST MANAGEMENT INDUSTRIAL HYGIENE: JOHN A. JURGIEL & ASSOCIATES, INC.	200 SOUTH HANLEY ROAD, STE. 1105, CLAYTON, MISSOURI 63105, 314-862-2112		Date Checked Drawn APRIL 13, 2015 DAVLAR KEIEVE	Dwg. 136 of 142	Department of Veterans Affairs










## DATA ROOM ENLARGEMENT HC-1


CONTRACTOR SHALL MOUNT GROUND BAR (SC-GND-W) AT 7'-0" AFF.
 CONTRACTOR SHALL PROVIDE FIRE RATED PATHWAYS AS NEEDED FOR CABLING

3. REFER TO 2/T401 FOR DATA ROOM PATHWAY ENLARGEMENT HC-1. 4. REFER TO 1/T501 FOR BONDING BUS BAR DETAIL. REFER TO 3/T501 FOR TECHNOLOGY BONDING RISER DIAGRAM.
 REFER TO 4/T501 FOR TELECOM ROOM BONDING FLOW DIAGRAM.






KEYNOTES:
1. THREE (3) 4" CONDUIT SLEEVES.



# **OI&T RACK ELEVATION HC-1**

NOTES:
1. REFER TO 2/T501 FOR TELECOM RISER DIAGRAM. <u>KEYNOTES</u>:

1. SPACE FOR OWNER PROVIDED EQUIPMENT.




## **SECURITY SYSTEMS RACK ELEVATION HC-1**

NOTES:
1. REFER TO 2/T501 FOR TELECOM RISER DIAGRAM.

KEYNOTES:

1. SPACE FOR OWNER PROVIDED EQUIPMENT.

2. PATCH PANEL RESERVED FOR CAMERA CABLE TERMINATIONS.




5	FMS RACK ELEVATION HC-1
<u>J</u>	NO SCALE <u>NOTES:</u> 1. REFER TO 2/T501 FOR TELECOM RISER DIAGRAM.
	KEYNOTES:  1. SPACE FOR OWNER PROVIDED EQUIPMENT.

		CONSULTANTS:
		HEALTHCARE PLANNERS: VOA ARCHITECTS
		MEPFP + TECH + STRUCT: KJWW CONSULTING ENGINEERS
		CIVIL ENGINEER: JD ENGINEERING
		COST ESTIMATING: MOSS CONSTRUCTION COST MANAGEMENT
ons:	Date	INDUSTRIAL HYGIENE: JOHN A. JURGIEL & ASSOCIATES, INC.



ARCHITECT:

rawing Title  ROOM ENLARGEMENTS -	Project Title RENOV	ATE AND E		Project Number 549-130	
TECHNOLOGY		AYBURN ME ERANS CEN		Building Number  1	
pproved: Project Director	Location BONHAM, TEXAS			Drawing Number	
	Date	Checked	Drawn	T401	
	APRIL 13, 2015	DAVLAR	KEIEVE	Dwg. 139 of	142



FROM MCR-1 > - - -FROM MCR-1 > - - -\_\_\_\_\_\_ \_ \_ \_ \_ \_ \_ \_ \_\_ \_\_ FROM MCR-1 > - -SC-FDC-1 PROVIDED **PROVIDED** PROVIDED **EQUIPMENT EQUIPMENT EQUIPMENT** SC-MPP-1 SC-MPP-1 SC-MPP-1 HC-1 OI&T HC-1 SECURITY HC-1 FMS

TELECOM RISER DIAGRAM


6. 200-PAIR COPPER.

THIS RISER IS DIAGRAMMATIC AND MAY NOT SHOW ACTUAL ROUTING OR QUANTITIES OF MATERIALS SHOWN.
 THIS RISER IS SHOWN FOR CLARIFICATION OF CONNECTION(S), LOCATIONS AND CABLE TYPE. ALL INFORMATION
 OUTLETS ARE TYPICAL OF THE OUTLETS IN THE AREA SHOWN. REFER TO FLOOR PLANS FOR MORE SPECIFIC
 ROUTING INFORMATION. REFER TO SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS.
 REFER TO FLOOR PLANS FOR QUANTITY OF CABLES AND JACKS TO BE INSTALLED AT EACH INFORMATION
 OUTLET.
 REFER TO COVERPAGE AND FLOOR PLANS FOR TELECOMMUNICATIONS ROOM LOCATIONS.


KEYNOTES:
 "X X" INDICATES VOICE/DATA FACEPLATE CONFIGURATION. REFER TO THE INFORMATION OUTLET SCHEDULE ON T000 FOR ADDITIONAL INFORMATION. REFER TO ELECTRICAL FLOOR PLANS AND ELECTRICAL EQUIPMENT SCHEDULE FOR ADDITIONAL INFORMATION.
 CAMERA LOCATION. REFER TO THE INFORMATION OUTLET SCHEDULE SCHEDULE ON T000 FOR ADDITIONAL INFORMATION. REFER TO ELECTRICAL FLOOR PLANS AND ELECTRICAL EQUIPMENT SCHEDULE FOR ADDITIONAL INFORMATION.
 REFER TO SPECIFICATIONS FOR FIBER PATCH CORD REQUIREMENTS.
 RJ-45 TO RJ45 CATEGORY 6

12SM/24LOMM/24MM FIBER OPTIC CABLE.
 24LOMM/24MM FIBER OPTIC CABLE.
 REFER TO SPECIFICATIONS FOR COPPER PATCH CORD REQUIREMENTS.

5. 23 GAUGE 4-PAIR, CATEGORY 6, UNSHIELDED TWISTED PAIR CABLE, REFER TO SPECIFICATIONS.



REFER TO TECHNOLOGY EQUIPMENT SCHEDULE <u>SC-GND-W</u> FOR WIDTH REQUIREMENTS.
REFER TO 4/T501 FOR TELECOMMUNICATIONS ROOM BONDING FLOW DIAGRAM.



## TECHNOLOGY ROUGH-IN MOUNTING DETAIL

NO SCALE

1. INSTALL ROUGH-IN AT 18" A.F.F. UNLESS OTHERWISE NOTED OF FLOOR PLANS

# TYPICAL TELECOM ROOM BONDING FLOW DIAGRAM

NOTES:

1. THIS FLOW DIAGRAM IS DIAGRAMMATIC AND MAY NOT SHOW ACTUAL ROUTING OR QUANTITIES OF MATERIALS. THIS FLOW DIAGRAM IS SHOWN FOR CLARIFICATION OF CONNECTION LOCATIONS AND CONDUCTOR TYPE. ALL CONNECTIONS AND SYSTEM DEVICES SHOWN ARE TYPICAL AND NOT REPRESENTATIVE OF ACTUAL PROJECT QUANTITIES. REFER TO FLOOR PLANS AND ENLARGED FLOOR PLANS FOR ACTUAL QUANTITIES AND LOCATIONS OF DEVICES AND MORE SPECIFIC ROUTING INFORMATION. REFER TO

ALL CONDUCTORS IN THE TECHNOLOGY BONDING SYSTEM SHALL BE MINIMUM SIZE OF 3/0 AWG PLENUM RATED COPPER (GREEN OR MARKED WITH A DISTINCTIVE GREEN COLOR) UNLESS CONDUCTOR LENGTH IS LESS THAN 66 FEET. REFER TO BONDING CONDUCTOR SIZING SCHEDULE FOR SIZING CRITERIA FOR CONDUCTORS LESS THAN 66 FEET IN LENGTH. REFER TO SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS.
 ALL BONDING CONDUCTORS AND BONDING JUMPERS SHALL BE CONNECTED BY COMPRESSION LUGS, EXOTHERMIC WELDING, OR

IRREVERSIBLE COMPRESSION CONNECTORS. SOLDER IS NOT AN ACCEPTABLE MEANS OF CONNECTION. SHEET METAL SCREWS SHALL NOT BE USED TO CONNECT COMMUNICATIONS BONDING CONDUCTORS TO EQUIPMENT. WHERE NECESSARY, REMOVE PAINT AND/OR USE PAINT-PIERCING WASHERS TO PROVIDE PROPER ELECTRICAL BOND AT ALL CONNECTIONS.

4. REFER TO 1/T501 FOR BONDING BUS BAR DETAIL AND ADDITIONAL INFORMATION AND REQUIREMENTS FOR SC-GND-W.


SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS.

VA FORM 08-6231, OCT 1978


KEYNOTES:
1. REFER TO TELECOM ROOM REFERENCES SCHEDULE ON DRAWING T000 FOR TELECOMMUNICATIONS ROOM NUMBER AND

INCLUDES HORIZONTAL AND VERTICAL CONDUIT SLEEVES FOR TECHNOLOGY CABLING.
 TELECOMMUNICATIONS BONDING BACKBONE (TBB). REFER TO 3/T501 FOR TELECOMMUNICATIONS BONDING RISER DIAGRAM.
 BONDING CONDUCTOR FOR TELECOMMUNICATIONS (BCT), TO EXISTING ELECTRICAL ENTRANCE INTERSYSTEM BONDING TERMINATION. REFER TO 3/T501 FOR TELECOMMUNICATIONS BONDING RISER DIAGRAM FOR CONTINUATION AND ADDITIONAL

REFER TO THE ELECTRICAL DRAWINGS FOR LOCATION.
 PROVIDE <u>SC-GND-2</u> RACK MOUNT TELECOMMUNICATIONS BONDING BUSBAR AT EACH EQUIPMENT RACK AND CABINET.



7 CABLE RUNWAY RADIUS DROP



## TECHNOLOGY BONDING RISER DIAGRAM

EXISTING ELECTRICAL GROUNDING

THIS RISER IS DIAGRAMMATIC AND MAY NOT SHOW ACTUAL ROUTING OR QUANTITIES OF MATERIALS.
 THIS RISER IS SHOWN FOR CLARIFICATION OF CONNECTION LOCATIONS AND CONDUCTOR TYPE. ALL
 CONNECTIONS AND SYSTEM DEVICES SHOWN ARE TYPICAL AND NOT REPRESENTATIVE OF ACTUAL
 PROJECT QUANTITIES. REFER TO FLOOR PLANS AND ENLARGED FLOOR PLANS FOR ACTUAL
 QUANTITIES AND LOCATIONS OF DEVICES AND MORE SPECIFIC ROUTING INFORMATION. REFER TO
 SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS.
 ALL CONDUCTORS IN THE TECHNOLOGY BONDING SYSTEM SHALL BE MINIMUM SIZE OF 3/0 AWG
 PLENUM RATED COPPER (GREEN OR MARKED WITH A DISTINCTIVE GREEN COLOR) UNLESS
 CONDUCTOR LENGTH IS LESS THAN 66 FEET. REFER TO BONDING CONDUCTOR SIZING SCHEDULE
 FOR SIZING CRITERIA FOR CONDUCTORS LESS THAN 66 FEET IN LENGTH. REFER TO SPECIFICATIONS


FOR ADDITIONAL REQUIREMENTS.

3. ALL BONDING CONDUCTORS AND BONDING JUMPERS SHALL BE CONNECTED BY COMPRESSION LUGS, EXOTHERMIC WELDING, OR IRREVERSIBLE COMPRESSION CONNECTORS. SOLDER IS NOT AN ACCEPTABLE MEANS OF CONNECTION. SHEET METAL SCREWS SHALL NOT BE USED TO CONNECT COMMUNICATIONS BONDING CONDUCTORS TO EQUIPMENT. WHERE NECESSARY, REMOVE PAINT AND/OR USE PAINT-PIERCING WASHERS TO PROVIDE PROPER ELECTRICAL BOND AT ALL

 REFER TO 4/T501 FOR TYPICAL TELECOM ROOM BONDING FLOW DIAGRAM.
 REFER TO TELECOM ROOM REFERENCES SCHEDULE ON DRAWING T000 FOR TELECOMMUNICATIONS ROOM NUMBER AND LOCATION INFORMATION.

KEYNOTES:
BONDING CONDUCTOR FOR TELECOMMUNICATIONS (BCT). BCT SHALL BE THE SAME SIZE AS THE TBB OR LARGER. REFER TO BONDING CONDUCTOR SIZING SCHEDULE FOR SIZING REQUIREMENTS.

BONDING CONDUCTOR SIZING SCHEDULE			
CONDUCTOR LENGTH IN FEET	MINIMUM ACCEPTABLE SIZE - AWG		
LESS THAN 13'	6		
14' - 20'	4		
21' - 26'	3		
27' - 33'	2		
34' - 41'	1		
42' - 52'	1/0		
53' - 66'	2/0		
GREATER THAN 66'	3/0		



# CONTROLLED SECURITY SCHEME DOOR ROUGH-IN DETAIL

OTES:

CONFIGURATIONS SHOWN IN THE DETAIL ABOVE ARE DIAGRAMMATIC, INTENDED TO DESCRIBE THE CONTROLLED SECURITY SCHEME ROUGH-IN REQUIREMENTS OF THE DOORS. DETAILS ABOVE MAY NOT ACCURATELY REPRESENT DOOR SIZE, DOOR SWING, DOOR HARDWARE, OR DOOR FUNCTIONALITY. REFER TO ARCHITECTURAL DOOR HARDWARE SCHEDULE, DOOR HARDWARE GROUPS AND DOOR HARDWARE SPECIFICATIONS FOR COMPLETE INFORMATION. MIRROR THE DETAIL AS REQUIRED.

ROUGH IN SHOWN IN THE DETAIL ABOVE REPRESENTS THE MINIMUM REQUIREMENTS FOR ALL CONTROLLED SECURITY SYSTEM DEVICES AND CABLING

UNLESS OTHERWISE NOTED. COORDINATE EXACT REQUIREMENTS WITH SELECTED DOOR MATERIALS, DOOR HARDWARE, AND CONTROLLED SECURITY DEVICES AND CABLING PRIOR TO INSTALLATION.

3. ALL CABLING IN WALLS AND WHERE EXPOSED ON VERTICAL SURFACES SHALL BE INSTALLED IN EMT CONDUIT OR SURFACE MOUNT RACEWAY. CABLING ROUTED HORIZONTALLY ABOVE THE ACCESSIBLE CEILING MAY BE INSTALLED FREE-AIR CABLING PROPERLY RATED FOR THE CEILING ENVIRONMENT.

4. THE ELECTRICAL OR SECURITY CONTRACTOR SHALL NOT MODIFY ON FIRE RATED DOOR AND/OR DOOR FRAME. REFER THE ACCESSIBLE OF THE AC

SCHEDULE, DOOR HARDWARE SCHEDULE, AND DOOR HARDWARE SPECIFICATION FOR ADDITIONAL INFORMATION. MODIFICATION TO ANY FIRE RATED DOOR AND/OR FRAME WILL REQUIRE A RE-CERTIFICATION OF THE DOOR AND FRAME WITH THE LOCAL AUTHORITY HAVING JURISDICTION (AHJ).

5. INSTALLING CONTRACTOR SHALL FURNISH AND INSTALL FIRESTOP MATERIALS FOR ALL CONTROLLED SECURITY SCHEME ROUGH-INS PER PROJECT REQUIREMENTS. REFER TO SPECIFICATIONS FOR ADDITIONAL INFORMATION AND REQUIREMENTS.

6. REFER TO THE ACCESS CONTROL RISER DIAGRAM ON 2/T502 FOR CABLING REQUIREMENTS AND THE CONTROLLED SECURITY SCHEME SCHEDULE ON T601

REFER TO THE ACCESS CONTROL RISER DIAGRAM ON 2/T502 FOR CABLING REQUIREMENTS AND THE CONTROLLED SECURITY SCHEME SCHEDULE OF FOR ADDITIONAL INFORMATION.
 INSTALLATION SHALL INCLUDE ALL POWER REQUIRED FOR SYSTEM OPERATION INCLUDING +120VAC. REFER TO THE SUGGESTED MATRIX OF SCOPE RESPONSIBILITY FOR ADDITIONAL INFORMATION.

KEYNOTES:

1. PROVIDE JUNCTION BOXES IN THE DOOR FRAME WHERE SHOWN ON THIS DETAIL. ROUGH-IN SHALL BE PROVIDED WHETHER THE CURRENT SECURITY SCHEME UTILIZES THEM OR NOT. ALL CONDUITS SHALL BE EMT CONDUIT UNLESS OTHERWISE NOTED. FLEXIBLE CONDUIT OF ANY TYPE WILL NOT BE ACCEPTED. COORDINATE INSTALLATION WITH ON-SITE DOOR FRAME INSTALLATION CONTRACTOR.

2. ALL DOOR POSITION SWITCHES ARE REQUIRED TO BE RECESSED UNLESS OTHERWISE NOTED. ELECTRIC HINGE MONITORS ARE NOT AN ACCEPTABLE

REPLACEMENT FOR THE RECESSED DOOR POSITION SWITCH.

3. DOUBLE GANG BACKBOX WITH SINGLE GANG PLASTER RING. REFER TO FLOOR PLAN(S) FOR ACTUAL CREDENTIAL READER TYPE AND ROUGH-IN LOCATIONS.


4. CONDUIT SHALL ROUTE FROM THE CREDENTIAL READER TO THE SECURE SIDE OF THE DOOR. CONDUIT SHALL ROUTE TO THE NEAREST TELECOM SECURITY ROOM.

ROOM.
5. MOUNT A MINIMUM 4" SQUARE 2-1/8" DEEP JUNCTION BOX WITH BLANK COVER PLATE ON THE SECURE SIDE OF THE DOOR ABOVE ACCESSIBLE CEILING.
INSTALLING CONTRACTOR SHALL SIZE THE JUNCTION BOXES PER SYSTEM INSTALLATION REQUIREMENTS AND APPLICABLE CODES. MAINTAIN ACCESS TO THE JUNCTION BOX.

6. PROVIDE A HORIZONTALLY MOUNTED SINGLE GANG BACKBOX FOR THE REQUEST TO EXIT SENSOR. REFER TO THE CONTROLLED SECURITY SCHEME

SCHEDULE ON T601 FOR DOORS THAT REQUIRE THIS ROUGH-IN.
7. CONDUIT SHALL ROUTE TO THE NEAREST TELECOM SECURITY ROOM.
8. CONDUIT INSTALLED IN PERMANENT MULLIONS ONLY. REFER TO THE ARCHITECTURAL DOOR SCHEDULE AND DOOR HARDWARE GROUPS FOR LOCATIONS THAT REQUIRE THIS ROUGH-IN. PROVIDE A NYLON BUSHING ON THE CONDUIT END.

	CONSULTANTS:  HEALTHCARE PLANNERS: VOA ARCHITECTS  MEPFP + TECH + STRUCT: KJWW CONSULTING ENGINEERS  CIVIL ENGINEER: JD ENGINEERING  COST ESTIMATING: MOSS CONSTRUCTION COST MANAGEMENT  INDUSTRIAL HYGIENE: JOHN A. JURGIEL & ASSOCIATES, INC.	ARCHITECT:	DETAILS - TECHNOLOGY	Project Title RENOVATE AND EXPAND  AMBULATORY CARE AND LAB.	Project Number 549-130	Facilities
		MICHAEL ROTH & ASSOCIATES.				
		ARCHITECTS & PLANNERS, INC.	Approved: Project Director	Location BONHAM, TEXAS	Drawing Number T501  Dwg. 140 of 142	
Revisions:		200 SOUTH HANLEY ROAD, STE. 1105, CLAYTON, MISSOURI 63105, 314-862-2112		Date Checked Drawn APRIL 13, 2015 DAVLAR KEIEVE		Department of Veterans Affairs



CONTROLLED SECURITY SCHEME (CSS) TYPE SCHEDULE  ELECTRONIC DOOR HARDWARE SUCH AS ELECTRIC STRIKES, ELECTRIC LATCH RETRACTION, ETC. SHALL BE PROVIDED AND INSTALLED BY OTHERS. REFER TO THE TECHNOLOGY SCHEDULE ON X/XXX FOR CREDENTIAL READER TYPE INFORMATION.  CREDENTIAL READER INTEGRATION EXIT DOOR HARDWARE OTHER  OTHE	GY EQUIPMENT
SCHEDULE ON X/XXX FOR CREDENTIAL READER TYPE INFORMATION.  REQUEST TO DOOR HARDWARE OTHER  OO OO USE OF THE STATE OF THE S	PGY EQUIPMENT
CREDENTIAL READER INTEGRATION EXIT DOOR HARDWARE OTHER	
SINGLE DOOR RRIDE	
SINGLE SINGLE SINGLE	
SINGE SINGE	
SINGE SINGE	
$oxed{I}$	
OPERATES S SEQUENCE IASTER IASTER ITCH ITCH	
SEQUE	
ADERS OPE RS SWITCH SP SWI	
NTIAL READERS ( NTIAL READERS	
ER TYPE  ER TYPE  ER TYPE  ER TYPE  TIAL READEF  LE DOORS  LE DOORS  ING HARDWA  ING HARDW	
ER TYPE  ER TYPE  ER TYPE  TIAL READ  TIAL R	
I ONLY  I ONLY  IAL READER TYP  IAL READER TYP	
S MULTIFE S MULT	
HIN ONLY  NTIAL READER T  NTIA	
H-IN ONLY  ENTIAL READER TYPE  ENTIAL READER TYPE  PLE CREDENTIAL READERS OPERA  ATES MULTIPLE DOORS  ESS  MATIC DOOR OPERATOR  TOR DOOR OPERATOR  TE UNLOCK VIA INTERCOM MASTE SION DETECTION  TE UNLOCK VIA INTERCOM MASTE OR DOOR HARDWARE (BY C  OCK  1 SURVEILLANCE  IN DETECTOR  TE UNLOCK VIA FIRE COMMAND CB  SOLOR HARDWARE (BY C  OCK  1 STATUS DETECTION  TOR DOOR POSITION SWITCH PPDT  TOR DOOR POSITION SWITCH PODT  TOR MAGNETIC POSITION SWITCH  TED EGRESS  L 120VAC POWER SUPPLY  DULE BASED LOCKING	
HED   CAL LAYE   SINTOCK   TO   MOT   MO	
######################################	
1-1 • S No	
1-2 • S No	
1-3	
1-5 S No • • • • • • • • • • • • • • • • • •	
1-6 • S No	
1-8 SK No DUAL AUTENTICATION	
1-9 SK No DUAL AUTENTICATION	
1-10 SK No DUAL AUTENTICATION 1-11 • S No	
1-12 • S No	
1-13	
1-14	
1-16 • S No	
1-17	
1-19 S No S No S No S S	
1-20 S No • • • • • • • • • • • • • • • • • •	

	GENERAL TECHNOLOGY EQUIPMENT SCHEDULE  AMES AND THE TECHNOLOGY EQUIPMENT SCHEDULE ARE FOR THE CONVENIENCE OF	
	WHETHER SPECIFIED OR NOT, TO PRODUCE A SATISFACTORY WORKING SYSTEM.  BERS SHALL NOT BE CONSIDERED COMPLETE BUT ARE GIVEN ONLY TO AID THE CONTRACTORY	*
NATERIAL. NO I	MATERIAL SHALL BE ORDERED BY MANUFACTURER AND CATALOG NUMBER ONLY. EACH COMPLETE DESCRIPTION OF THE MATERIAL ON THESE DRAWINGS AND SPECIFICATIONS. THE INTERPRETATION OF THE MATERIAL ON THESE DRAWINGS AND SPECIFICATIONS. THE INTERPRETATION OF THE MATERIAL ON THESE DRAWINGS AND SPECIFICATIONS. THE INTERPRETATION OF THE MATERIAL ON THESE DRAWINGS AND SPECIFICATIONS.	NTRACTOR SHALL FIRST FIRST MANUFACTURER
EQUIPMENT LIST		EQUIPMENT LIST MANUFACTURER AND
ABBREVIATION	EQUIPMENT LIST DESCRIPTION	MODEL
AC-AUD-SRV	RACK MOUNTED AUDIO SERVER FOR IP EMERGENCY INTERCOM STATIONS. PROVIDE WITH GLOBAL NETWORKING AND INTEGRATION, SIM CARD BASED SOFTWARE CONFIGURATION AND DISASTER RECOVERY, SUPPORT FOR UP TO 512 STATIONS, EXTENDED MEMORY FOR FUTURE EXPANSION, MESSAGING SERVICES, AND AUTO-ATTENDANT FUNCTIONALITY. PROVIDE SOFTWARE LICENSES AS REQUIRED FOR THIS PROJECT.	*
AC-CR1-W	CARD READER, PROVIDED AS INTEGRAL PART OF SECURITY MANAGEMENT SYSTEM, REFER TO ACCESS CONTROL SYSTEM DOOR SCHEDULE FOR COMPLETE INFORMATION, CARD READERS SHOWN ON PLANS TO IDENTIFY INTENDED MOUNTING LOCATION, REFER TO SPECIFICATION SECTION 28 13 00 FOR COMPLETE INFORMATION.	*
AC-FO-TX	FIBER OPTIC TRANSCEIVER, MULTI-MODE FIBER OPTIC ST TO RJ45 COPPER TRANSCEIVER - FULL DUPLEX, HARDENED, TEMPERATURE RANGE - 10° TO 50° C.	*
AV-IO-W	AV OUTLET	*
NC-D-C	INSTALL INFORMATION OUTLET IN A 4" SQUARE BACKBOX WITH A SINGLE GANG PLASTER RING. INSTALL A 1" EMT CONDUIT BETWEEN UPPER AND LOWER AV OUTLETS, REFER TO AV OUTLET DETAIL ON 4/T502. CONTRACTOR SHALL VERIFY WALLPLATE COLOR WITH ARCHITECT. REFER TO SPECIFICATIONS FOR LABELING REQUIREMENTS.  NURSE CALL DOME LIGHT CEILING MOUNTED. DETECTION LIGHT INDICATING CALLS FROM PATIENT STATIONS, TOILETS, SHOWERS, DUTY STATIONS, ETC. LEDS TO PROVIDE HIGH-VISIBILITY ANNUNCIATION OF PATIENT CALLS. COLOR PATTERNS AND FLASH RATES OF THE LEDS ARE PROGRAMMABLE. REFER TO FLOOR PLANS FOR DEVICE LOCATIONS. E.C. TO PROVIDE 3-GANG (NON-GANGABLE) 3 1/2" DEEP BACKBOX WITH 3/4" EMT CONDUIT. UTILIZE STEEL CITY (58371) OR APPROVED EQUAL. REFER TO %NCRN% ON %NCRR.	*
NC-DTY-W	NURSE CALL DUTY STATION. STATION PROVIDED AND INSTALLED BY OTHERS. REFER TO FLOOR PLANS FOR DEVICE MOUNTING HEIGHT AND LOCATIONS. E.C. TO PROVIDE 3-GANG (NON-GANGABLE) 3 1/2" DEEP BACKBOX WITH 3/4" EMT	*
NC-E	CONDUIT TO ABOVE ACCESSABLE CEILING. REFER TO %NCRN% ON %NCRR.  NURSE CALL CODE BLUE CALL STATION, WITH CANCEL PUSH BUTTON AND BLUE PAD PUSH BUTTON LABELED "CODE	*
NC-MAS-W	BLUE".  NURSE CALL MASTER STATION, DESK MOUNT, MICROPROCESSOR BASED WITH L.C.D. READOUT, REFER TO	*
NC-NCP-1	SPECIFICATIONS FOR ADDITIONAL INFORMATION.  NURSE CALL CENTRAL EQUIPMENT. INCLUDES CONTROL EQUIPMENT SUCH AS GATEWAYS, ROUTERS, SWITCHES, ETC.	*
	RACK OR WALL MOUNT DEPENDANT UPON MANUFACTURER REQUIREMENTS, 120 VOLT, WITH INTERNAL BATTERY  BACK-UP, REFER TO SPECIFICATIONS FOR ADDITIONAL INFORMATION, ALL FIELD WIRING SHALL BE TERMINATED UNDER	
NC-T-W	THE SUPERVISION OF NURSE CALL AUTHORIZED REPRESENTATIVE.  NURSE CALL PATIENT ASSIST WITH PULL CORD CALL STATION. EMERGENCY PULL CORD STATION WITH CANCEL PUSH BUTTON FOR USE IN TOILETS. WATERPROOF FOR TOILET USE. REFER TO FLOOR PLANS FOR DEVICE MOUNTING HEIGHT. E.C. TO PROVIDE 1-GANG (NON-GANGABLE) 3 1/2" DEEP BACKBOX WITH 3/4" EMT CONDUIT TO ABOVE	*
PA-S-C	ACCESSABLE CEILING. UTILIZE STEEL CITY (58371) OR APPROVED EQUAL.  SPEAKER, RECESS CEILING MOUNT ASSEMBLY, CONSISTING OF AN 8" LOUDSPEAKER, 10 OZ. CERAMIC MAGNET.  47-20kHz FREQUENCY RANGE, 15 WATTS RMS RATING, 120 DEGREE COVERAGE ANGLE. 70V TRANSFORMER TAPS 5W, 2W, 1W, 0.5W, 0.25W INCLUDES SPEAKER BACKBOX, BAFFLE AND WHITE STEEL GRILL. PROVIDE A SPEAKER SUPPORT	*
00 514 4	BRIDGE FOR LAY-IN CEILINGS. SUBSCRIPT INDICATED PAGING ZONE.	
SC-EM-1	EMERGENCY INTERCOM STATION. VANDAL RESISTANT EMERGENCY POWER. LIGHT/STROBE INSTALLED IN ACRYLIC HOUSING LED LIGHTING FOR FACEPLATE. STEEL WITH MULTI-COAT RUST INHIBITIVE COATING. STROBE - 1.5 MILLION CANDLE POWER. 20 FLASHES PER SECOND. BLUE LIGHT - 7 WATT HIGH EFFICIENCY, 10,000 HOUR COMPACT FLUORESCENT. COLOR AND LETTERING TO BE COORDINATED WITH OWNER PRIOR TO INSTALLATION. PROVIDE WITH CAMERA DOME AT THE TOP OF THE TOWER. IP-SUBSTATION. ONE BUTTON CALL INTEGRATED WEB SERVER. REMOTE	
	SOFTWARE UPGRADEABLE AND MONITORING, WIDE BANDWIDTH FOR AUDIO, VANDAL RESISTANT.	
SC-ER-1	STANDARD 19" EQUIPMENT RACK, 84"H X 19"W X 3"D, FEATURING PASS-THRU HOLES ON FRONT AND SIDES FOR CABLE MANAGEMENT, DURABLE BLACK POWDER COAT FINISH, MEETS EIA-310-E REQUIREMENT AND PROVIDES (45) 19" X 1.75" MOUNTING SPACES.	*
	PROVIDE WITH TOP CENTER WATERFALL, TOP CHANNEL PATHWAY FOR LADDER RACK, AND ANY ADDITIONAL HARDWARE FOR COMPLETE INSTALLATION. REFER TO SPCIFICATIONS SECTION 27 11 00 FOR ADDITIONAL INFORMATION.	
SC-FDC-1	OPTICAL FIBER DISTRIBUTION CABINET., 96 FIBER MINIMUM CAPACITY, FRONT LOCKING DOOR, SLIDE OUT RAILS TO FACILITATE FRONT ACCESS, JUMPER THROUGHS IN CONNECTOR PANELS TO REDUCE MOUNTING SPACE. REQUIRES FOUR (4) 19" X 1.75" RACK MOUNTING SPACES.	*
	PROVIDE WITH CLAMP AND GROUNDING KIT, COUPLING PANELS, [ST][SC][FC][MT-RJ][LC][HIGH DENSITY] CONNECTOR,	
SC-GND-2	COUPLINGS AND JUMPERS. REFER TO SPECIFICATIONS SECTION 27 11 00 FOR ADDITIONAL INFORMATION.  HORIZONTAL RACK GROUND BUSBAR. 19" RACK MOUNT. EIGHT (8) 6-32 UNF LUG MOUNTING HOLES. PROVIDE WITH	*
SC-GND-W	INSULATORS, MOUNTING HARDWARE AND LUG MOUNTING HARDWARE.  WALL-MOUNT GROUND BAR. 4" H X 12" L X 1/4" D COPPER, ELECTRICALLY ISOLATED BY INSULATORS INTEGRAL TO MOUNTING BRACKETS. COPPER GROUND BAR IS 1/4" THICK AND STAND OFF 2.75" FROM WALL. THE 12" BUSBAR PROVIDES CONNECTION FOR NINE LUGS RESPECTIVELY WITH 3/4" OR 1" OR 1-3/4" CENTERS. ANSI/EIA/TIA-607 AND BICSI COMPLIANT.	*
	ULLISTED.     REFER TO 1/T501 FOR ADDITIONAL INFORMATION.	
SC-HWM-1	HORIZONTAL WIRE MANAGEMENT, 1.5" X 3" PRE-ASSEMBLED D-RINGS ON FRONT, 1.5" X 5" PRE-ASSEMBLED D-RINGS ON REAR. PROVIDE WITH COVER. REQUIRES (1) 1.75" MOUNTING SPACE	*
SC-IO-C	INFORMATION OUTLET, CEILING MOUNT, 2-PORT COVERPLATE AS INDICATED ON DRAWINGS, SEE INFORMATION OUTLET DETAILS T000 FOR PIN CONFIGURATION. "#" INDICATES INFORMATION OUTLET FACEPLATE CONFIGURATION AS INDICATED ON THE PLANS. SEE INFORMATION OUTLET SCHEUDLE T000.	*
	INSTALL INFORMATION OUTLET IN A 4" SQUARE BACKBOX WITH A SINGLE GANG PLASTER RING. INSTALL A 1" EMT CONDUIT 6" BEYOND BOX AND TERMINATE WITH A NYLON BUSHING. PROVIDE REMOVABLE BLANK INSERTS FOR UNUSED	
SC-IO-F	PORTS.  INFORMATION OUTLET, FLOOR MOUNT, INSTALLED IN E.C. PROVIDED AND INSTALLED FLOOR BOX. COVERPLATE AS	*
	INDICATED ON DRAWINGS, SEE INFORMATION OUTLET DETAILS T000 FOR PIN CONFIGURATION. "#" INDICATES INFORMATION OUTLET FACEPLATE CONFIGURATION AS INDICATED ON THE PLANS. SEE INFORMATION OUTLET SCHEUDLE T000.	
2.5	INSTALL A 1" EMT CONDUIT FOR DATA CABLING FROM FLOOR BOX TO ABOVE ACCESSIBLE CEILING SPACE PROVIDE WITH NYLON BUSHING.	
SC-IO-W	INFORMATION OUTLET, WALL MOUNT, COVERPLATE AS INDICATED ON DRAWINGS, SEE INFORMATION OUTLET DETAILS T000 FOR PIN CONFIGURATION. "#" INDICATES INFORMATION OUTLET FACEPLATE CONFIGURATION AS INDICATED ON THE PLANS. SEE INFORMATION OUTLET SCHEUDLE T000.	*
00.1100.4	INSTALL INFORMATION OUTLET IN A 4" SQUARE BACKBOX WITH A SINGLE GANG PLASTER RING. INSTALL A 1" EMT CONDUIT TO ABOVE ACCESSIBLE CEILING SPANCE, PROVIDE WITH A NYLON BUSHING. PROVIDE REMOVABLE BLANK INSERTS FOR UNUSED PORTS.	
SC-MPP-1	MODULAR PATCH PANEL, 48 MODULAR RJ-45 TERMINATIONS, MOUNTS DIRECTLY TO EIA/TIA STANDARD 19" RELAY RACK, PORT IDENTIFICATION NUMBERS, PROVIDED WITH COLOR CODING AND LABEL HOLDER KITS, U.L. LISTED. REQUIRES (2) 1.75" MOUNTING SPACES.	
SC-RD-1	CABLE RUNWAY RADIUS DROP. ATTACHES TO SIDE OF RUNWAY, 3" BEND RADIUS. PROVIDE WITH 1-1/2" CABLE SPOOLS TO SEPARATE AND GUIDE CABLES.	*
SC-TTB	TELECOMMUNICATIONS TERMINAL BOARD, 4' X 8' X 3/4" A-C GRADE FIRE-RATED PLYWOOD. EXPOSED SIDE SHALL BE SMOOTH. MOUNT VERTICALLY WITH TOP OF PLYWOOD AT 8'6" A.F.F.	*
SC-VPP-1	VOICE PATCH PANEL, 110-TYPE 100-PAIR, PROVIDE WITH MOUNTING BLOCKS, CONNECTING BLOCKS, HORIZONTAL JUMPER TROUGHS, DUCT ASSEMBLIES, HARDWARE, LABEL HOLDERS, AND BLANK INSERTS, REFER TO SPECIFICATIONS FOR ADDITIONAL INFORMATION. ALSO PROVIDE WITH 110-TYPE PATCH PANEL SYSTEM BACKBOARD.	*
SC-VWM-1	VERTICAL WIRE MANAGER, 7'H X 6"W X 12.5"D. REMOVABLE FRONT COVER HINGES ON LEFT OR RIGHT. SPOOLS FOR INTEGRAL BEND RADIUS CONTROL.	*
SC-WAP-C	INFORMATION OUTLET, CEILING MOUNT, 2-PORT, COVERPLATE AS INDICATED ON DRAWINGS, INTENDED TO PROVIDE CONNECTIVITY FOR FUTURE WIRELESS ACCESS POINT. REFER TO DRAWING T000 FOR INFORMATION OUTLET SCHEDULE. SEE DETAILS INFORMATION OUTLET SCHEDULE FOR PIN CONFIGURATION.	*
SC-WP-W	INSTALL INFORMATION OUTLET IN A 4" SQUARE BACKBOX WITH A SINGLE GANG PLASTER RING, MOUNT TO CLOSEST STRUCTURAL ELEMENT (EX. COLUMN). INSTALL A DELUXE CORD GRIP FOR STRAIN RELIEF ON UTP CABLE. PROVIDE 20' COIL OF UTP CABLE AT WIRELESS OUTLET LOCATION. PROVIDE REMOVABLE BLANK INSERTS FOR UNUSED PORTS.  INFORMATION OUTLET, WALL PHONE OUTLET, 1-PORT COVERPLATE AS INDICATED ON DRAWINGS AND INFORMATION OUTLET SCHEDULE, REFER TO T000 FOR PIN CONFIGURATION INFORMATION.	*
	" W "PROVIDE (1) RJ-45 JACK FOR VOICE AT +48" AFF FOR WALL HUNG PHONE. PROVIDE WITH STAINLESS STEEL	
	FACEPLATE, MATING LUGS. REFER TO T000 FOR ADDITIONAL INFORMATION.	
	INSTALL INFORMATION OUTLET IN A 4" SQUARE BACKBOX WITH A SINGLE GANG PLASTER RING. INSTALL A 1" EMT CONDUIT TO %COND% OR UNLESS OTHERWISE NOTED. PROVIDE REMOVABLE BLANK INSERTS FOR UNUSED PORTS.	

	CONSULTANTS:	ARCHITECT:  MICHAEL ROTH & ASSOCIATES, ARCHITECTS & PLANNERS, INC. 200 SOUTH HANLEY ROAD, STE. 1105, CLAYTON, MISSOURI 63105, 314-862-2112	Drawing Title	Project Title RENOVATE AND EXPAND AMBULATORY CARE AND LAB.	Project Number 549-130	
	HEALTHCARE PLANNERS: VOA ARCHITECTS  MEPFP + TECH + STRUCT: KJWW CONSULTING ENGINEERS		SCHEDULES - TEHCNOLOGY	SAM RAYBURN MEMORIAL  VETERANS CENTER	Building Number  1	Office of Facilities
	CIVIL ENGINEER: JD ENGINEERING  COST ESTIMATING: MOSS CONSTRUCTION COST MANAGEMENT  INDUSTRIAL HYGIENE: JOHN A. JURGIEL & ASSOCIATES, INC.		Approved: Project Director	Location BONHAM, TEXAS	Drawing Number	Management
Revisions: Date				Date APRIL 13, 2015  Checked Drawn KEIEVE	T601 Dwg. 142 of 142	Department of Veterans Affairs

 1
 2
 3

 5
 8